

Special Use Permit for Open Flame Special Events

1. Clearance from combustibles must be provided and maintained.
2. Candles are prohibited in areas where occupants stand, or in an aisle or exit.
3. Hand-held candles shall not be passed from one person to another while lighted.
4. Draperies, curtains, furnishings, and decorations shall be flame resistant.
5. Fire retardant coatings shall be maintained to retain the effectiveness of the treatment under conditions encountered in actual use.
6. Exposed foamed plastic materials and unprotected materials containing foamed plastic used for decorative purposes or stage scenery shall have a heat release rate not exceeding that specified in UL 1975.
7. Open flame decorative devices shall comply with Section 308.3.2, Chapter 3, of the 2003 International Fire Code.
8. Provide a fire watch during the event and for a minimum of ½ hour after the event to ensure no fires have been started.
9. A minimum of two fire extinguishers with a rating of 2A10BC are required. The extinguishers must have current tags with the State of Nevada seal.

Additional requirements are subject to inspection and review of the event.